


# NZ Power Industry Space Weather Operational Response

TRANSPower



CEP2025, Andrew Renton May 2025

# Agenda

- Takeaways
- Who is Transpower
- GIC Context & risk
- What are we doing
- Plans for the future






# Takeaways

## Take aways

- No human health impacts at ground level - only to technical infrastructure, but with effects varying across the country and lasting from 24 to 36 hours. If you already have an emergency plan for dealing with disruptions to your lifeline services from flooding, earthquake, volcanic eruption, or tsunami, then you already have an effective plan for extreme space weather.
- GPS positioning and time services, LEO satellite and some terrestrial comms (HF, VHF radio) will be impacted, any functions relying on these will be degraded during the event.
- Transpower is the electricity sector coordinating entity, takes the industry technical/operational lead with government agencies (DPMC, NEMA, ODESC) during event response.
- Known historical phenomena. Last extreme event 1859, before grids existed. Growing scientific and engineering understanding of the HILP risk posed to modern interconnected systems and each affected asset owner, which must be addressed collaboratively to provide electricity to end consumers.
- Tight collaboration between scientific community and electricity participants required (Transpower close involvement since 2016 & Solar Tsunami Project 2019/20). Electricity Industry Space Weather Working Group established 2023, after science could provide answers to engineering questions. Goal to provide a coherent industry response and assurance to Government that the risk is adequately addressed and mitigated.
- Design level event is 1:100 with Transpower designing for 1:450 flooding, 1:2500 earthquake, 1:300 year wind








# Country & Company Overview




## Aotearoa, New Zealand

- Land area 220,000sqkm/108,000sqml
- Population 5.2M
- GDP NZ\$262B/US\$155B
- Seismically active, maritime, volcanic, flat lands to mountains (3,750m/12,500') fiords
- Rainfall 300mm/2,800mm pa
- Average Solar resource 11-14MJ/m2/day
- Average Wind 4-6m/s windfarm capacity factors 0.32-0.48
- Plan for many natural hazards earthquakes, tsunamis, volcanic, flooding, space weather






# NZ electricity industry is horizontally split



# Transmission network

- NZ\$4.9 billion regulated transmission assets
- Sole Transmission System Owner & Operator in New Zealand
- Approximately 11,000 kilometres of transmission lines
- 1,200MW HVDC Bi-Pole, 600km link
- 178 substations
- 27 distribution customers
- 10 large industrial direct-connect customers
- 6 large grid-connected generator customers
- Installed generation capacity 9,271 MW
- Peak demand 7,000MW,
- Annual generation 43,503 GWh
- 82% Renewable generation








# GIC Context & Risk




# How does it interact with electricity network?




- A planet sized generator using Faradays law.
- An electric current produces a magnetic field
- The magnetic field produces a voltage in the ground
- Voltage differences (10-30V/km) between the ground points drives a current between them
- The current takes the path of least resistance either the ground or long metal connection like our transmission lines
- This is why it is mostly a generator and transmission issue (generators connected to ends of lines)
- Saturates transformers, heating, reactive power draw, equipment damage and voltage collapse

## Changing Magnetic Fields Induce an Electric Current







# What is the impact on other infrastructure?



# The physical threat



We're for New Zealand. Tū mai Aotearoa.


2000/02/27 01:54





# Environment @ the time

- Carrington event 1859
- Bulledale & Refton 1886/8
- Repair crew 1902 for the 1897 11kV 42km Buffalo-Niagra



**The Auroral Display in Boston.**  
Boston, Friday, Sept. 2.  
There was another display of the Aurora last night, so brilliant that at about one o'clock ordinary print could be read by the light. The effect continued through this forenoon, considerably affecting the working of the telegraph lines. The auroral currents from east to west were so regular that the operators on the Eastern lines were able to hold communication and transmit messages over the line between this city and Portland, the usual batteries being discontinued from the wire. The same effects were exhibited upon the Cape Cod and other lines.

*The New York Times*  
Published: September 3, 1859  
Copyright © The New York Times




**We're for New Zealand. Tū mai Aotearoa.**

- We're for New Zealand. Tū mai Aotearoa.**

### PROBABILITY OF OCCURRING IN NEXT 50 YEARS

- Alpine fault 75%
- **Extreme CME 64%**
- Mt Taranaki eruption 30-50%
- Hikurangi fault 25%



# NOAA geomagnetic storm scale

**NZ Extreme event 4,000nT/min**

**Near miss 2012 1,500nT/min**

**Hydro Quebec 550nT/min**

**Gannon 390-420nT/min**

Transpower mitigation plan initiates switching

Transpower mitigation plan monitors  
Aurora visible from Christchurch

Scale	Description	Effect	Physical measure	Average Frequency (1 cycle = 11 years)
<b>G 5</b>	<b>Extreme</b>	<p><b>Power systems:</b> Widespread voltage control problems and protective system problems can occur, some grid systems may experience complete collapse or blackouts. Transformers may experience damage.</p> <p><b>Spacecraft operations:</b> May experience extensive surface charging, problems with orientation, uplink/downlink and tracking satellites.</p> <p><b>Other systems:</b> Pipeline currents can reach hundreds of amps, HF (high frequency) radio propagation may be impossible in many areas for one to two days, satellite navigation may be degraded for days, low-frequency radio navigation can be out for hours, and aurora has been seen as low as Florida and southern Texas (typically 40° geomagnetic lat.).</p>	Kp = 9	4 per cycle (4 days per cycle)
<b>G 4</b>	<b>Severe</b>	<p><b>Power systems:</b> Possible widespread voltage control problems and some protective systems will mistakenly trip out key assets from the grid.</p> <p><b>Spacecraft operations:</b> May experience surface charging and tracking problems, corrections may be needed for orientation problems.</p> <p><b>Other systems:</b> Induced pipeline currents affect preventive measures, HF radio propagation sporadic, satellite navigation degraded for hours, low-frequency radio navigation disrupted, and aurora has been seen as low as Alabama and northern California (typically 45° geomagnetic lat.).</p>	Kp = 8, including a 9-	100 per cycle (60 days per cycle)
<b>G 3</b>	<b>Strong</b>	<p><b>Power systems:</b> Voltage corrections may be required, false alarms triggered on some protection devices.</p> <p><b>Spacecraft operations:</b> Surface charging may occur on satellite components, drag may increase on low-Earth-orbit satellites, and corrections may be needed for orientation problems.</p> <p><b>Other systems:</b> Intermittent satellite navigation and low-frequency radio navigation problems may occur, HF radio may be intermittent, and aurora has been seen as low as Illinois and Oregon (typically 50° geomagnetic lat.).</p>	Kp = 7	200 per cycle (130 days per cycle)
<b>G 2</b>	<b>Moderate</b>	<p><b>Power systems:</b> High-latitude power systems may experience voltage alarms, long-duration storms may cause transformer damage.</p> <p><b>Spacecraft operations:</b> Corrective actions to orientation may be required by ground control; possible changes in drag affect orbit predictions.</p> <p><b>Other systems:</b> HF radio propagation can fade at higher latitudes, and aurora has been seen as low as New York and Idaho (typically 55° geomagnetic lat.).</p>	Kp = 6	600 per cycle (360 days per cycle)
<b>G 1</b>	<b>Minor</b>	<p><b>Power systems:</b> Weak power grid fluctuations can occur.</p> <p><b>Spacecraft operations:</b> Minor impact on satellite operations possible.</p> <p><b>Other systems:</b> Migratory animals are affected at this and higher levels; aurora is commonly visible at high latitudes (northern Michigan and Maine).</p>	Kp = 5	1700 per cycle (900 days per cycle)



# Recent damaging events

## North America 13 March 1989

- CME 3-5 times smaller than an “extreme event”
- 1.5 minutes Hydro-Quebec system collapsed, transformers damaged



## NZ 6th November 2001 14:53pm

- CME 20-30 times smaller than an “extreme event”
- HWB T4 destroyed (unrepairable), ISL SVC tripped



Variation of the Earth's magnetic field  
Measured at GNS Science's geomagnetic observatory in Canterbury


The May 2024 magnetic storm compared to storms in 1989 and 2001






## Changes overtime

- Sun has 11 year cycle
- Extreme storms can occur at anytime
- Most occurring descending phase
- Space is getting a lot busier
- Loss of time, position and sky is real



## Satellite Operations & Major Storms


### What Changed?



- Rapid expansion in low LEO (400-1000 km).
- Satellite operations have changed a lot.
  - Starlink: 50,000 collision avoidance maneuvers in the first half of 2024.





# Risks to the electricity industry



# Model of NZ Power System

- All generator and transmission ccts, transformers, and earth grids
- 1989 Event scaled to 4,000nT/min with Rogers latitude correction
- GIC profile by unit, triaged IEEE C57 and our derived current limits



# Ttransformer threat assessments

- Hitachi Energy, Dr Girgis & Mats Bernesjo undertook independent design checks, GIC magnetic assessment, design susceptibility, structural thermal impacts, winding thermal impacts.
- 27 units at risk of catastrophic failure




Figure 4

[Open in figure viewer](#) | [PowerPoint](#)

Example showing geomagnetically induced current (GIC)/temperature relationship. The Blue line indicates temperature and the red is the magnitude of GIC/phase. From Marti et al. (2013).




Figure 4—Calculated Thermal response of T6 Transformers at Halfway Bush to GIC Signature of Figure 2




Figure 6—Calculated Hot Spot Temperature of Structural parts of North Makarewa T1 & T2 Transformers






---

**What have we and are we doing?**

# SCADA & GIC



- Original HVDC link installed 1965
- First 12 GIC monitors installed 1992 as part HVDC upgrade, expanded after 2001 event
- Monitor GIC currents at 72 TX over 29 sites country wide, based on initial modelling
- Adding 10 more TX at 7 sites HEN T1, T3 SFD T10, RDF T1 & T2, KAW T12, KIK T1, WIL T8, STK T1 & T2, based on results of solar tsunami modelling, 20+ years real time data



# Joint testing DC Injection Testing

- Two injection campaigns 2023 & 2025
- 4 periods of 2hrs at 700A DC
- Monitoring multiple 3 phase transformers for GIC, vibration, audio and VLF radio
- Details of 1<sup>st</sup> and 2<sup>nd</sup> campaigns
- <https://solartsunamis.otago.ac.nz/2023/01/first-injection-campaign/>



# Operational switching plan – predicted result

Using actual data to:

- Validated and published plan PR-DP-252 & PR-DP-1077
- Extrapolate to compare to historical record
- Compare to NERC & Carrington events
- Scenario using scaled 1989 event, winter peak demand, full security, objective minimise total system GIC and peak GIC in most at threat assets, by switching assets out of service

Document Status: **Issued**

Operations Division

**PR-DP-1077 Industry response to a geomagnetic storm**

This Procedure is part of the Dispatch (DP) process within Transpower and forms part of the System Operator and Grid Operations function. The document can be found in the [Operational Documents Library](#).

Document Status: **Issued**

Published Date: **17/07/2024**

Table of Contents

1. Purpose	2
2. Regional Procedures	4
2.1 Scenario 1: Manage an extreme GIC event (G3 / 4y)	4
3. Appendix	5
3.1 Key assumptions	8
3.2 Regional context information	8
3.3 Warnings and Alerts	9
3.4 Solar activity background information	14
4. Document Information	14
4.1 Copyright Information	14
4.2 Document Feedback	14
4.3 Revision History	14
4.4 Metadata	15

Doc File Name: PR-DP-1077 Industry response to a geomagnetic storm.docx  
Location/Version code: PR-DP-1077/V1

Printed on: 11/08/24  
Page 1 of 15

Document Status: **Issued**

Operations Division

**PR-DP-252 Manage Geomagnetic Induced Currents**

This Procedure is part of the Dispatch (DP) process within Transpower and forms part of the System Operator and Grid Operations function. The document can be found in the [Operational Documents Library](#).


Document Status: **Issued**

Published Date: **5/07/2023**

Table of Contents

1. Purpose	2
2. Regional Procedures	4
2.1 Manage Pre-Event	4
2.2 Manage a Moderate to Severe GIC Event (G2)	4
2.3 Manage a Moderate to Severe GIC Event (G3)	4
2.4 Manage an extreme GIC event (G3 / 4y)	4
2.5 Report events following an extreme event (G3 / 4y)	4
3. Appendix	18
3.1 GIN Template for section 3.2	18
3.2 GIN Template for section 3.4	19
3.3 Warnings and Alerts	21
3.4 Solar activity background information	24
3.5 SCADA Displays	26
4. Document Information	27
4.1 Copyright Information	27
4.2 Document Feedback	27
4.3 Revision History	27
4.4 Metadata	28

Doc File Name: PR-DP-252 Manage Geomagnetic Induced Currents.docx  
Location/Version code: PR-DP-252/V6  
Printed on: 11/08/24  
Page 1 of 28





# Information sharing & collaboration

- Development and hosting of shared industry knowledge basket for joint collaboration

The screenshot shows a web browser window displaying the 'Industry GIC Knowledge Store' on a SharePoint site. The browser's address bar shows the URL: <https://transpowernz.sharepoint.com/sites/external/gampd236e/SitePages/Home.aspx>. The page header includes the 'theVOLT' logo, the 'SharePoint' branding, and a search bar. Below the header, the page title is 'Industry GIC Knowledge Store' with an 'EDIT LINKS' option. The main content area is divided into three columns. The left column contains a navigation menu with links: Home, GIC data, Industry Response, Transpower information, Contact, Genesis, Harmonic Analytics, Mercury, Meridian, Otago University, University of Wellington, University of Canterbury, and Solar Flare Report. The middle column features a large heading 'About' followed by a paragraph: 'ECHO, External Collaboration Hub Online, is Transpower's SharePoint Online environment for collaboration with authorised external stakeholders.' Below this is a heading 'Important information' followed by a paragraph: 'This service is managed and the use of this service is governed under the Transpower external site-usage and access policies.' The right column has a heading 'Contact Details' followed by a list item: 'Andrew Renton, Senior Principal Engineer'. Below this is a heading 'Site Users' followed by a list of names: 'Brendan Olsen', 'Brighid Kelly', 'Byron George', 'Carina Toscano', 'Chantelle Bramley', and 'Cobus Nel'. Each name is preceded by a small square icon.

theVOLT SharePoint

Search this site

BROWSE PAGE

SHARE FOLLOW EDIT

Industry GIC Knowledge Store EDIT LINKS

Industry GIC Knowledge Store

Home

GIC data

Industry Response

Transpower information

Contact

Genesis

Harmonic Analytics

Mercury

Meridian

Otago University

University of Wellington

University of Canterbury

Solar Flare Report

About

ECHO, External Collaboration Hub Online, is Transpower's SharePoint Online environment for collaboration with authorised external stakeholders.

Important information

This service is managed and the use of this service is governed under the Transpower external site-usage and access policies.

Contact Details

☐ Andrew Renton  
Senior Principal Engineer

Site Users

☐ Brendan Olsen

☐ Brighid Kelly

☐ Byron George

☐ Carina Toscano

☐ Chantelle Bramley

☐ Cobus Nel

# Operational situational awareness tools

- Developing displays for TX GIC, TX Temp, present and predicted solar wind/magnetic field change






**Our response today**

# Possible event timeline






# Possible event timeline



- When an event occurs scientists and NOAA will be aware of it within 10min, with WATCH notices issued of "G4 or Greater" (highest prediction possible)
- Effectively blind until L1 where first instruments are available to measure velocity, density, polarity to confirm magnitude is small G5 (Gannon 350-500nT/min) or Design Level G5 (4,000nT/min). NOAA will issue a WARNING notice at this point





# Possible event impact today




- When an event occurs scientists and NOAA will be aware of it within 10min, with WATCH notices issued of "G4 or Greater" (highest prediction possible)
- Effectively blind until L1 where first instruments are available to measure velocity, density, polarity to confirm magnitude is small G5 (Gannon 350-500nT/min) or Design Level G5 (4,000nT/min). NOAA will issue a WARNING notice at this point
- Confirmation of event occurs after it is practical to undertake any mitigations or to manage with lighter touch

# Mitigation response plan

- Transpower have a procedure to “manage geomagnetically induced currents” (PR-DP-252), published to reduce magnitude GIC in transmission system. It covers monitoring space weather, outage recalls, calling GEN, and switching to reduce GICs.
- Asset owners generally plan to connect more assets so GIC is shared across more neutrals, lessening its effect – successful in up to moderate events, but in extreme events will put more assets at risks.
- Generators have now prepared their own business response plan. Outputs of these are input to Transpower's whole of industry (PR-DP-1077) and Transpower (PR-DP-252) response plans.
- The new joint industry response plan is published (PR-DP-1077). Includes event trigger, pre-impact coordination, identification of asset owner equipment removal levels, Government co-ordination, demand management and reference to restoration sequences.



# How an event would play out today









**Gannon Storm 10-13 May 2024**


# “Gannon” 10-12 May ‘24, Mag Field and GIC LEM monitoring results



Site	Spike 1	Spike 2
Awarua	343 nT/min	318 nT/min
Swampy	287 nT/min	281 nT/min
Eyrewell	320 nT/min	130 nT/min



# "Gannon" 10-12 May '24, GIC LEM monitoring results





# Peak GIC with switching plan implemented

- Work in Progress undertaking back calculation to see impact with/without switching plan & with/without SDN T2
- SDN T2 Tripped 05:28

**HWB T6 GIC Neutral Current (A)**  
(Calculated, *Actual measured*)

System Config	SDN T2 In	SDN T2 Out
No mitigation	137A	211A
With mitigation	41A	103A
Actual	N/A	<b>113A</b>

*Note T3 peaked at 100A, total site GIC 213A mitigated  
Unmitigated site of approx. 430A*





# Operational response summary

## Friday 10 May:

- 09:15: NEMA contact control room in relation to 'solar flare watch'. No action as only a 'watch' and trigger is 'warning' or 'alert'

## Saturday 11 May:


- **04:53: First NOAA 'solar flare warning' (G2 – moderate) issued. More warnings and alerts follow**
- 05:28: South Dunedin transformer trips (turns out to be unrelated)
- **05:58: NOAA Alert K8-9**
- 06:19: Transformer GIC alarms trigger at several sites (sign of storm)
- More NOAA warnings and current alarms occur
- 09:00: Grid Emergency Notice (GEN) issued. Enable switching of circuits in SI
- **11:37: NOAA 'ALERT' (K9/G5 – extreme) issued**
- 12:01: Second GEN issued. Enable switching of circuits in NI
- 13:30: SO Industry briefing – inform industry
- **14:50: NOAA 'ALERT' (G5 – extreme) issued, more warnings and alerts follow**

## Sunday 12 May:

- Continue to monitor storm, after consultation with Otago Uni decide to end GENs on Monday morning 04:00

## Monday 13 May:

- 04:00: GENs ended






# Work to do & improvements



# Improvements for event management 0-5 years



# GIC blocking device

- Can be installed on transformer neutral to block GICs
- Currently prototypes only we have number 4 being installed
- Large footprint; not suitable for some sites (e.g. Manapouri)
- ATC Wisconsin reporting it has worked well for last 8 years (for small GICs to date).
- NZ\$1.5-2M install per transformer.





# Development of local/regional impacts for NEMA

## Local Auckland Impact

PR-DP-252 & PR-DP-1077

- BHL-WKM\_A removed from service
- RDF-WRK\_A removed from service

### Sites that have elevated mean GIC >200-300A


- This level is higher than desired needs close and active monitoring and could cause loss of supply. Peak currents up to 550A
- Henderson 1ph (HEN 140MW), Glenbrook 3ph (GLN 110+80MW), Pakuranga 3ph (PAK 160MW) most susceptible sites,
- If loss of supply occurs then will remain off for duration of event 24-36hrs

### Sites that have mean GIC <200-300A

- Rest of AKL sites 70-150A higher than preferred but manageable
- Should be of low risk e.g. Takanini, Penrose, Otahuhu, Wiri, Mangere etc with minimal chance of disruption

Installing additional sensors at OTA, GLN, HEN, power system studies to consider mitigations effectiveness

Even if Auckland sites fully available may have supply disruption should wider Grid impacts require response that reduces generation and therefore demand management required





# Q&A

We're for New Zealand. Tū mai Aotearoa.



---

# Appendices